


**DIVIDED ROADWAY
(90' RIGHT-OF-WAY)**
NTS

NOTES:

1. TRANSVERSE SAWED CONTRACTION JOINTS AT 15' INTERVALS AND LONGITUDINAL SAWED CONTRACTION JOINTS 12' FROM OUTSIDE BACK OF CURBS.
- * 2. LIME SHALL BE APPLIED AT 6% BY WEIGHT. MINIMUM QUANTITY IS 36#/SY. IN SOME AREAS A GREATER QUANTITY (OR A LIME SERIES TEST) MAY BE REQUIRED AT THE CITY'S DISCRETION.
- ** 3. CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 30#/SY.

REVISIONS	Revised 11/16/99 (Bar Size & Pavement Layer Thicknesses)
 CITY OF ARLINGTON, TEXAS	
PROJECT NUMBER PROJECT NAME (PROJECT LIMITS)	
DATE:	SHEET: <u> </u> OF <u> </u>
DESIGNED BY:	CHECKED BY: