

Approved Double Check List

Manufacturer	Type	Model No.	Size
Ames	DC	C200	2½"-10"
Ames	DC	C200N	2½"-10"
Ames	DC	C200a	2½"-6"
Ames	DC	C200Na	2½"-6"
Ames	DC	3000SS	2½"-12"
Apollo	DC	40-100-T2	¾" - 2"
Apollo	DC	4D-100	2½"-6"
Apollo	DC	DC 4S	2½"-10"
Cla-Val	DC	D-4	2½"-10"
Conbraco	DC	4D-100	2½"-6"
Conbraco	DC	DC	2½"-10"
Febco	DC	850	2½"-10"
Febco	DC	870 / 870V	2½"-10"
Watts	DC	719	2"
Watts	DC	757a	2½"-6"
Watts	DC	757Na	2½"-6"
Watts	DC	007	2"-3"
Watts	DC	709	2½"-10"
Watts	DC	757, 757N	2½"-10"
Watts	DC	774	2½"-12"
Wilkins	DC	450	4"-10"
Wilkins	DC	450	2½",3"
Wilkins	DC	450BGVIC	4"-8"
Wilkins	DC	950	2½",3",8",10"
Wilkins	DC	950XLOS	2"
Wilkins	DC	950XLU	2"
Wilkins	DC	950XLTCU	2"
Wilkins	DC	950XL	2"
Wilkins	DC	475	4",6",8"
Wilkins	DC	475VBGVIC	4",6",8"
Wilkins	DC	350	2½"-12"
Wilkins	DC	350A	2½"-10"

Or approved equal double check device conforming to USC, ASSE 1013, AWWA C511 or CSA CAN/CSA-B64.4.

Please submit additional device request with the appropriate conforming proof to:

Dean Yanagi
Chair of Product Review Committee
fax 817-459-6633