



NOTES:

1. ALL CONNECTIONS SHALL BE FLANGED OR MJ RESTRAINED WITH APPROVED RETAINER GLANDS OR THRUST RESTRAINT DEVICES.
2. ALL PIPING TO BE DUCTILE IRON WITH ALL BURIED VALVE, PIPE & FITTINGS TO BE POLY-WRAPPED.
3. FIRE HYDRANT BONNET TO BE BRUSH PAINTED (DO NOT SPRAY) WITH 2 COATS OF RUST-OLEUM TRUE BLUE (1626830).
4. OPEN GATE VALVE TO FIRE HYDRANT TO BE USED FOR FIRE PROTECTION.
5. IF VERTICAL PIPE IS GREATER THAN 6 FEET, A FLANGED VERTICAL SHOE/ENTRY BASE HYDRANT SHALL BE USED WITH A FLGxFLG DUCTILE IRON PIPE AND A 90° BEND. VERTICAL SHOE TO BE INSTALLED AT 4 FEET MAXIMUM DEPTH TO BOTTOM FLANGE.

CITY OF ARLINGTON, TEXAS
BLOW OFF USING FIRE HYDRANT
DATE: 10/02/2019