



ELEVATION

(PLAN VIEW SAME AS SANITARY SEWER SERVICE ON SANITARY SEWER SERVICE DETAIL)

NOTES:

1. CLASS "B" EMBEDMENT REQUIRED FOR SEWER MAIN AND SERVICE LINE WITHIN EASEMENT OR ROW UNLESS OTHERWISE NOTED.
2. SERVICES SHALL BE SDR-26 PVC PIPE.
3. NEW SERVICE TAPS ON EXISTING MAINS REQUIRE INSERTA-TEE CONNECTION OR APPROVED EQUAL.
4. SERVICES 8" AND LARGER REQUIRE A MANHOLE TO CONNECT TO MAIN UNLESS OTHERWISE APPROVED BY WATER UTILITIES.



CITY OF ARLINGTON, TEXAS

**DEEP SANITARY
SEWER SERVICE**

DATE: 11/19/2018