


WATER
SANITARY SEWER
VERTICAL FIBERGLASS MARKER



VALVE MARKER
(SEE NOTE 1)



VALVE AND FIRE HYDRANT MARKER LOCATIONS
(SEE NOTES THIS DETAIL)

NOTES:

1. EACH WATER SYSTEM VALVE LOCATED ADJACENT TO OR IN A CITY STREET SHALL RECEIVE A VALVE MARKER (FURNISHED BY THE CITY) PLACED ON THE FACE OF CURB AS CLOSE AS POSSIBLE TO THE VALVE USING MANUFACTURER RECOMMENDED ADHESIVE.
2. EACH LOCATION OF A FIRE HYDRANT SHALL RECEIVE A BLUE REFLECTORIZED MARKER LOCATED IN THE CENTER OF ANY STREET TO WHICH IT IS ADJACENT (2 FOR HYDRANTS ON STREET CORNERS).
3. ALL BLUE FIRE HYDRANT MARKERS SHALL BE A CUBE CORNER TYPE REFLEX REFLECTOR MOLDED OF OPTIC GRADE PLASTIC, WITH A HOUSING OF HIGH IMPACT ABS PLASTIC, WITH A FILLER OF INERT THERMOSETTING RESINS. APEX UNIVERSAL, INC. TYPE: BB TWO WAY BLUE.
4. VERTICAL FIBERGLASS MARKERS REQUIRED ONLY IN UNDEVELOPED AREAS OR AT DIRECTION BY ARLINGTON WATER UTILITIES. SEE GATE VALVE AND MANHOLE DETAILS.