



**ADDENDUM NO. 1  
to the Plans and Specifications for**

**Oak Street Water and Sanitary Sewer (Randol Mill Road to Cedar Street)**

**City of Arlington Project No. WUWS20009**

**January 10, 2022**

The following instructions shall constitute **Addendum No. 1** to the Plans and Specifications for the above titled project. **The Bidder shall acknowledge receipt of the addendum in the appropriate spaces provided on the last page of this addendum and include the acknowledgement/acceptance with the sealed bid. Addendum not acknowledged will be considered non-responsive and the bid will not be considered for award.** They shall supersede any and all instructions and shall become as much a part of the Plans and Specifications as though written therein. The successful bidder shall also acknowledge acceptance of the addendum on the final contract:

**I. REVISION TO SECTION NO. 2:**



ELECTRICIAN.....\$ 13.26

Form Setter.....\$ 7.86

Laborers:

    Common.....\$ 7.25

    Utility.....\$ 8.09

PAINTER.....\$ 10.89

Pipelayer.....\$ 8.43

Power equipment operators:

    Backhoe.....\$ 11.89                   3.30

    Bulldozer.....\$ 10.76

    Crane.....\$ 13.16                   3.30

    Front End Loader.....\$ 10.54

    Mechanic.....\$ 10.93

    Scraper.....\$ 10.00

Reinforcing Steel Setter.....\$ 10.64

TRUCK DRIVER.....\$ 7.34

---

WELDERS - Receive rate prescribed for craft performing  
operation to which welding is incidental.

---

THE STATE OF TEXAS §  
COUNTY OF \_\_\_\_\_ §

**AFFIDAVIT**

BEFORE ME, the undersigned authority, a Notary Public in and for the State of Texas, on this day personally appeared \_\_\_\_\_,  who is known to me or  who was proved to me on the oath of \_\_\_\_\_ (name of person identifying the acknowledging person) or  who was proved to me through \_\_\_\_\_ (description of identity card or other document issued by the federal or state government containing the picture and signature of the acknowledging person) to be the person whose name is subscribed to this affidavit; and being by me first duly sworn, upon oath stated as follows:

"My name is \_\_\_\_\_. I am of sound mind and capable of making this affidavit.

"I am \_\_\_\_\_ for \_\_\_\_\_, which company entered into a contract on the \_\_\_ day of \_\_\_\_\_, 20\_\_\_, to construct **OAK STREET WATER AND SANITARY SEWER (RANDOL MILL ROAD TO CEDAR STREET)**, City of Arlington Project No. **WUWS20009**, in the City of Arlington, Texas, and I am duly authorized on behalf of said company to hereby swear and affirm that all wages for labor on the above-referenced project are in strict compliance with the established prevailing wage rates as described in the contract documents for the referenced project, and all wages have been and will be paid and satisfied as the prevailing rates may change from time to time. Upon request by the City of Arlington, I shall allow a complete examination of the financial records relative to this project, including, but not limited to, cancelled checks, invoices and statements at any time, and allow the City of Arlington to interview any and/or all employees of the above said company or any and/or all employees of said Company's subcontractor or subcontractors. Also, I hereby agree on behalf of the above company, to be accountable for any and all penalties and/or fine provisions in accordance with the contract documents and relevant law."

\_\_\_\_\_  
AFFIANT

GIVEN UNDER MY HAND AND SEAL OF OFFICE this the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_\_.

\_\_\_\_\_  
Notary Public In and For The State of Texas

\_\_\_\_\_  
Notary's Printed Name

END OF SECTION

## **II. REVISION TO SECTION 11, 12, AND 13:**

### **11-23 SATURDAY OR CITY HOLIDAY INSPECTION:**

#### **I. Holiday Schedule**

1. Below are holidays observed by the City of Arlington. Actual date/day that the holiday is observed changes yearly based on the calendar. No work will be permitted except in the most extreme circumstances and with prior approval from the Construction Services Manager. If approved to work on a holiday, the Saturday inspection rates will apply.

- » Martin Luther King Day
- » President's Day
- » Good Friday
- » New Year's Day
- » Memorial Day
- » Juneteenth
- » Independence Day
- » Labor Day
- » Thanksgiving Day
- » Thanksgiving Friday
- » Christmas Eve
- » Christmas Day

(Rev. 1/2022)

2. In addition to the above, no work will be permitted on the weekend adjoining a holiday that falls on Friday or Monday.

### **12-34 BACKFILL AND CLEANUP:**

D. All concrete shall be backfilled as soon as possible. If "honeycomb" appears, the Contractor shall grout back side to smooth out the surface within twenty-four (24) hours of form removal.

E. Where lines or services are laid in, along, or across street pavement the pavement shall be left in a clean and acceptable condition. At the end of each work day the Contractor shall sweep and/or wash the pavement to leave the roadway completely clean of dirt and debris. Dirt, debris, and/or wash water shall be collected for appropriate disposal and shall NOT be washed into waterways or storm drains. Other suitable methods of maintaining the pavement in a clean, unobstructed condition may be utilized by the Contractor. No additional payment will be made for cleaning of pavement. Backfill and clean-up shall be considered subsidiary to the work performed under this contract.

**13-10 CONCRETE CURB AND GUTTER:**

F. Refer to Section 13-16 for additional concrete specifications.

**13-11 VALLEY GUTTERS:**

C. Refer to Section 13-16 for additional concrete specifications.

**13-12 CONCRETE DRIVEWAYS:**

D. Refer to Section 13-16 for additional concrete specifications.

**13-13 CONCRETE SIDEWALKS:**

C. Refer to Section 13-16 for additional concrete specifications.

**13-14 BARRIER FREE RAMPS:**

D. Refer to Section 13-16 for additional concrete specifications.

**13-15 CONCRETE PANEL REPLACEMENT:**

E. Refer to Section 13-16 for additional concrete specifications.

**13-16 CONCRETE/CONCRETE PAVEMENT:**

A. DESCRIPTION:

1. This item shall consist of portland cement concrete pavement, panel replacement, sidewalk, driveways, retaining walls, etc., with reinforcement as shown on plans, with or without monolithic curbs, constructed as herein specified on the prepared subgrade or other base course in conformity with the lines, grades, thickness and typical cross-sections shown on plans. Concrete shall be considered of satisfactory quality provided:
  - a. it is made of materials accepted for the job,
  - b. in the proportions approved by the City and
  - c. mixed, placed, finished and cured in accordance with the requirements of this specification and meets the requirements herein specified.

F. CONCRETE MIXING AND PLACING:

1. Mixing Methods

b. Mobile batch and/or volumetric trucks will not be permitted for use for any concrete.

c. Central Mix: The aggregates, cement and water shall be measured separately, introduced into the mixer, and mixed for a period of not less than fifty (50) seconds nor more than ninety (90) seconds, measured from the time the last aggregate enters

the drum to the time discharge of the concrete begins. The required water shall be introduced into the mixing drum during the first fifteen (15) seconds of mixing. The entire contents of the drum shall be discharged before any materials of the succeeding batch are introduced.

d. Central Mix: The aggregates, cement and water shall be measured separately, introduced into the mixer, and mixed for a period of not less than fifty (50) seconds nor more than ninety (90) seconds, measured from the time the last aggregate enters the drum to the time discharge of the concrete begins. The required water shall be introduced into the mixing drum during the first fifteen (15) seconds of mixing. The entire contents of the drum shall be discharged before any materials of the succeeding batch are introduced.

f. The maximum size of the concrete batch, absolute volume, shall not exceed one hundred twenty percent (120%) of the rated size of the mixer (40.8 cubic feet maximum batch for the 34-cubic foot paver). Spilling of material from the mixer drum shall be corrected by reducing the size of the batch. Retempering or remixing of concrete will not be permitted.

g. The initial batch of concrete mixed after each time the mixer is washed out shall be enriched by additional mortar. The additional mortar shall be one (1) sack of cement and three (3) parts sand.

**III. CHANGE TO PROPOSAL – SECTION 6:**

**1. REVISE Base Bid Items**

ITEM NO.	DESCRIPTION	UNIT PRICE IN WORDS	QTY	UNIT	PRICES IN FIGURES	
					UNIT PRICE	TOTAL
401	Furnish & Install 8-inch Sanitary Sewer Line, PVC (SDR- 26, 115 psi, Green Color) by open cut, all depths, including trench, embedment, & backfill, complete and in place for the unit price of	_____ Dollars and _____ Cents	1,996	Linear Foot	\$	\$
403	Furnish & Install Trench Safety Systems for Sanitary Sewer Line for all depths, in accordance with the Trench Safety Plan & the latest OSHA Standards, complete and in place for the unit price of	_____ Dollars and _____ Cents	1,996	Linear Foot	\$	\$
404	Furnish & Install 8-inch PVC Sanitary Sewer Line by other than open cut, including pipe material, 20-inch steel casing pipe (0.3125-inch minimum wall thickness), stainless steel casing spacers (minimum three per joint), bore pit, & pressure grout, complete and in place for the unit price of	_____ Dollars and _____ Cents	72	Linear Foot	\$	\$

**2. DELETE Base Bid Items**

ITEM NO.	DESCRIPTION	UNIT PRICE IN WORDS	QTY	UNIT	PRICES IN FIGURES	
					UNIT PRICE	TOTAL
402	Furnish & Install 8-inch Sanitary Sewer Line, PVC (SDR- 26, 160 psi, Green Color) by open cut, all depths, including trench, embedment, & backfill, complete and in place for the unit price of	_____ Dollars and _____ Cents	695	Linear Foot	\$	\$



ACKNOWLEDGEMENT/ACCEPTANCE:

The undersigned does hereby agree to the additions, stipulations, and terms outlined in **ADDENDUM NO 1.** to the Plans and Specifications for the **Oak Street Water and Sanitary Sewer (Randol Mill Road to Cedar Street), City of Arlington Project No. WUWS20009.**

  
\_\_\_\_\_  
Sergio Quiroga  
Graduate Engineer  
Arlington Water Utilities

The bidder shall acknowledge his/her Addendum in the appropriate space below and **include it in the bid proposal otherwise the bid will be considered as non-responsive.**

Contractor:

\_\_\_\_\_  
Company

By \_\_\_\_\_  
Please Print

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Title - Please Print